

GOVERNMENT OF TELANGANA
ROADS & BUILDINGS DEPARTMENT

From :
Sri R.Chander Singh B.Tech
Executive Engineer(R&B),
Medchal Division.
Medchal - Malkajgiri District

To : ✓
The Manager
Jubilee Hills Public School
Rampally (V)
Keesara (M)

Lr. No.EE / (R&B)/DB/Medchal/2019-20 467 Date:06-07-2019

Sir,

Sub :- (R&B) Division, Medchal-Malkajgiri Dist Issue of Structural Soundness Certificate for Jubilee Hills Public School at Sy. Nos. 581/P, 582/P, 583/P at Rampally Dayara Village, Keesara Mandal, Medchal District. - Issue of Structural soundness certificate - Reg.

Ref:- 1) Requisition Lr. from Manager, Jubilee Hills Public School Dated 02-07-2019.
2) Inspection report from DyEE/Buildings vide Lr.NoDEE/(R7b)/Buildings/2019-20/77 Dated:05-07-2019

* * * * *

The Jubilee hills Public School has applied for issuance of Structural Soundness Certificate vide reference 1st cited. The DyEE/Buildings has inspected the said building and submitted the inspection report vide reference 2nd cited. It is reported by the DyEE/Buildings that it is a G+1 Building and few Cracks are observed in the building walls and front portico slab which should be repaired immediately to prevent any untoward incidents. Based on the Structural Soundness Certificate issued by J. Narayana Rao, License no. 312/strl. Engg/TP10/MCH. The Building is structurally sound and fit for running the school for a period of 5 (five) years only.

Yours faithfully,

Chandrababu
6/7/19

Dist (R&B) Officer,
Medchal-Malkajgiri Dist

Copy to the DyEE/Buildings for information and necessary action.

For Jubilee Hills Public School-Rampally

Suchantika Roy
Principal

Jubilee Hills Public School Rampally

Anusha
Chairman



SAAC

**STRUCTURAL
AND
ARCHITECTURAL
CONSULTANTS**

Flat No. 102, Susthira Lok, Opp. Mahalaxmi Theatre, Kothapet, Hyderabad, Ph: +91 90325 35230

STRUCTURAL SOUNDNESS CERTIFICATE

I, hereby certify that the school building consisting of Ground + 2 upper floors of M/s Jubilee Hills Educational Society, Rep By T.Harischandra Prasad, Block-III Road No.71, Jubilee Hills, Hyderabad, constructed in Sy.Nos.581/P, 582/P & 583/P of Rampally Village, KeesaraMandalMedchal District has been inspected by me. I declare that the building is structurally safe in all respects i.e., in respect of structurally safety, and stability and can be used for class rooms and other school activities.

The building validity period is up to 30 years ,with proper periodical maintenance under technical supervision to all RCC members. This certificate is invalid, if any subsequent alterations,repairs,expansions are made to the structure in any manner without notice.

For Jubilee Hills Public School-Rampally
Suchandra Roy
Principal

~~10/12/23~~ 19/1/23
J. NARAYANA RAO
M.Tech. (Struc.), M.I.E., C.E.
STRUCTURAL ENGINEER-MCH
No: 812/Strl.Engg./TP10/MCH-04

Jubilee Hills Public School Rampally
Musechandra
Chairman