

OFFICE OF THE DISTRICT MEDICAL AND HEALTH OFFICER,
MEDCHAL - MALKAJGIRI DISTRICT.


Rc.No. 210 / SHP / DM&HO / Medchal / Dist-2024-25.

Dated: 03 / 07 / 2024.

SANITARY CERTIFICATE

I here by certified that Our Health Supervisor inspected the **M/s Jubilee Hills Public School**, Located at Plot No. 581/P, 583/P, Rampally Dayara Village, Keesara Mandal, Medchal - Malkajgiri District building and premises and certify that the accommodation provided for each of the several classes is sufficient for maximum number of pupils taught therein, and is properly ventilated and lighted, that the building is maintained in substantial repairs, is neat and clean, that the urinals & latrine arrangements are adequate and satisfactory and the supply of Safe drinking water is wholesome, and in all other necessary respects the Hygienic and sanitation is in good condition, for the Academic Year 2024 - 25.

This certificate should be got renewed by the starting of every academic year by applying to the District Medical & Health Officer, Medchal District.


District Medical & Health Officer,
Medchal District, Telangana

For Jubilee Hills Public School, Rampally

Principal

For Jubilee Hills Public School, Rampally

M. Varalakshmi

Director



MACANA ANALYTICAL LABORATORY PRIVATE LIMITED
Flat No .210,1-75/5/211C,Sairam Nagar,Colony,Boduppall Village, Hyderabad,
Medchal-Malkajgiri,TelanganaState-500092,India.Near HP Petrol Bunk
Mobile No.9666572572 Email:canaanalyticallaboratory@gmail.com,
NABL Accredited Laboratory
ISO 9001:2015 Certified Laboratory - QMS/24M03210
ISO 45001:2018 Certified Laboratory- OHSAS/24M03211



Test Report

Report Number: MACANA-2025/201

Report Date:25 /01/2025

Customer Name & : **Jubilee Hills Public School**
Address : **Rampally Dayara . Keesara Mandal ,Mechal District ,Telangana – 501 301**
email : **info@jhpsrampally.com / WWW. jhpsrampally.com**
Contact : **9515943805**

Sample Name : **Bore Water (Parking)**
Reference Number : **NA** Sample Condition : **Good**
Sample/Lab Code : **MCAL/2025/000201** Sample Received on : **23/01/2025**
Sample Quantity : **1 Litre** Analysis Started on : **23/01/2025**
Sample Drawn by : **Customer** Analysis Completed on : **25/01/2025**

TEST RESULTS

S.No	Parameters	Test Method	Unit of Measurement	Results	Acceptable Limit(As per IS: 10500:2012
1	Colour	IS 3025-(part 4):1983	Hazen	BDL	Max 5.0
2	Taste	IS 3025-(part 8):2023	--	Agreeable	Odourless
3	Odour	IS 3025- part5):2018	--	Agreeable	Palatable
4	PH	IS 3025 (Part 11): 2022	--	6.88	6.5to 8.5
5	Electrical Conductivity	IS 3025 (Part14): 2013	µs/cm	901	---
6	Turbidity	IS 3025 (Part 10): 2023	NTU	<0.1	Max 1.0
7	Total Hardness	IS 3025 (Part21): 2009	mg/L	49.82	Max 200
8	Calcium as Ca	IS 3025 (Part40): 1991	mg/L	3.39	Max 75
9	Magnesium as mg	IS 3025 (Part46):2023	mg/L	9.201	Max 30
10	Chlorides	IS 025 (Part32): 1988	mg/L	72.44	Max 250
11	Total alkalinity	IS 3025: (Part 23): 2023	mg/L	161.5	Max 200
12	Total Dissolved Solids	IS 3025 (Part 38): 1989	mg/L	826	Max 500
13	Phosphate	IS 3025 (Part31):2022	mg/L	0.446	

For Jubilee Hills Public School, Rampally

Principal

For Jubilee Hills Public School, Rampally

M. Varalakshmi

Director



MACANA ANALYTICAL LABORATORY PRIVATE LIMITED
Flat No .210,1-75/5/211C,Sairam Nagar,Colony,Boduppall Village, Hyderabad,
Medchal-Malkajgiri,TelanganaState-500092.India.Near HP Petrol Bunk
Mobile No.9666572572 Email:canaanalyticallaboratory@gmail.com.
NABL Accredited Laboratory
ISO 9001:2015 Certified Laboratory - QMS/24M03210
ISO 45001:2018 Certified Laboratory- OHSAS/24M03211



Test Report

14	Fluoride	IS 3025 (Part 60): 2008	mg/L	0.520	Max 1
15	Sulphate	IS 3025 (Part 57): 2022	mg/L	20.13	Max 200
16	Nitrate	IS 3025 (Part 34): 1988	mg/L	4.362	Max 45
17	Sodium	IS 3025(part 45) :1983	mg/L	4.157	
18	Potassium	IS 3025(part 45) :1983	mg/L	3.120	

MICROBIOLOGICAL ANALYSIS

19	Coliforms	IS 15185 : 2016	Per 100ml	Absent	Absent/100 ml
20	Total bacteria lcount	IS 1622 :1981	Cfu/ml	85	Not Specified
21	E.Coli	IS 15185 :2016	Per 100ml	Absent	Absent/100 ml

Y. Anila
25/01/25
Analysed by
Y. Anila
Sr. Chemist



Sey 25-01-25
Authorized Signatory
N.Sathyanarayana
Quality Manager

Terms and conditions:

1. The test report shall not be reproduced in full or part without the written approval of Laboratory.
2. The test items will not be retained for more than 15 days from the date of issue of test report.
3. The test results relate only to the items tested as received.
4. The testing activities are performed in permanent facility located at Boduppall, Hyderabad.

*****END OF REPORT*****

For Jubilee Hills Public School, Rampally

Principal

For Jubilee Hills Public School, Rampally

H. V. Varalakshmi
Director



Test Report

Report Number: MACANA-2025/202

Report Date:25 /01/2025

Customer Name & : **Jubilee Hills Public School**

Address

: Rampally Dayara , Keesara Mandal ,Mechal District ,Telangana – 501 301

email : info@jhpsrampally.com / WWW. jhpsrampally.com
Contact : 9515943805

Sample Name	:Bore Water (Mango Graden)				
Reference Number	: NA	Sample Condition	: Good		
Sample/Lab Code	: MCAL/2025/000202	Sample Received on	: 23/01/2025		
Sample Quantity	: 1 Litre	Analysis Started on	: 23/01/2025		
Sample Drawn by	: Customer	Analysis Completed on	: 25/01/2025		

TEST RESULTS

S.No	Parameters	Test Method	Unit of Measurement	Results	Acceptable Limit(As per IS: 10500:2012
1	Colour	IS 3025-(part 4):1983	Hazen	BDL	Max 5.0
2	Taste	IS 3025-(part 8):2023	--	Agreeable	Odourless
3	Odour	IS 3025- part5):2018	--	Agreeable	Palatable
4	PH	IS 3025 (Part 11): 2022	--	6.74	6.5to 8.5
5	Electrical Conductivity	IS 3025 (Part14): 2013	µs/cm	1020	---
6	Turbidity	IS 3025 (Part 10): 2023	NTU	<0.1	Max 1.0
7	Total Hardness	IS 3025 (Part21): 2009	mg/L	207.74	Max 200
8	Calcium as Ca	IS 3025 (Part40): 1991	mg/L	3.00	Max 75
9	Magnesium as mg	IS 3025 (Part46):2023	mg/L	8.317	Max 30
10	Chlorides	IS 025 (Part32): 1988	mg/L	65.01	Max 250
11	Total alkalinity	IS 3025: (Part 23): 2023	mg/L	144.5	Max 200
12	Total Dissolved Solids	IS 3025 (Part 38): 1989	mg/L	831	Max 500
13	Phosphate	IS 3025 (Part31):2022	mg/L	0.474	

For Jubilee Hills Public School, Rampally

Principal

For Jubilee Hills Public School, Rampally

Director



MACANA ANALYTICAL LABORATORY PRIVATE LIMITED
 Flat No .210,1-75/5/211C,Sairam Nagar,Colony,Boduppall Village, Hyderabad,
 Medchal-Malkajigiri,TelanganaState-500092,India.Near HP Petrol Bunk
 Mobile No.9666572572 Email:canaanalyticallaboratory@gmail.com,
NABL Accredited Laboratory
ISO 9001:2015 Certified Laboratory - QMS/24M03210
ISO 45001:2018 Certified Laboratory- OHSAS/24M03211



Test Report

14	Fluoride	IS 3025 (Part 60): 2008	mg/L	0.551	Max 1
15	Sulphate	IS 3025 (Part 57): 2022	mg/L	19.43	Max 200
16	Nitrate	IS 3025 (Part 34): 1988	mg/L	3.973	Max 45
17	Sodium	IS 3025(part 45) :1983	mg/L	3.837	
18	Potassium	IS 3025(part 45) :1983	mg/L	2.743	

MICROBIOLOGICAL ANALYSIS

19	Coliforms	IS 15185 : 2016	Per 100ml	Absent	Absent/100 ml
20	Total bacteria lcount	IS 1622 :1981	Cfu/ml	92	Not Specified
21	E.Coli	IS 15185 :2016	Per 100ml	Absent	Absent/100 ml

Y. Anila 25/01/25
 Analysed by
 Y. Anila
 Sr. Chemist



Bay 25-01-25
 Authorized Signatory
 N.Sathyanarayana
 Quality Manager

Terms and conditions:

1. The test report shall not be reproduced in full or part without the written approval of Laboratory.
2. The test items will not be retained for more than 15 days from the date of issue of test report.
3. The test results relate only to the items tested as received.
4. The testing activities are performed in permanent facility located at Boduppall, Hyderabad.

*****END OF REPORT*****

For Jubilee Hills Public School, Rampally

[Signature]
 Principal

For Jubilee Hills Public School, Rampally

H. Varalakshmi
 Director